



DIMENSIONS ARE IN INCHES

Ultrasonic Monitor Ordering Information						
						Estimated Battery Life
	0	0	4	4 Minute transmit interval ⇔		1 Month
	0	3	0	30 Minute transmit interval ⇔		1 Year
	0	6	0	60 Minute transmit interval ⇔		2 Year
	1	2	0	120 Minute transmit interval ⇔		4 Year
	↓					
U M	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	E I 1 4 4	F 9	0 0 0 0

ETL Marked Intrinsically Safe apparatus for use in Class I, Division I, Group D applications, conforming to ANSI/UL 913-1988 Standard.

FCC Part 15 Registered: NU9TX0625-0200

This device complies with Part 15 of the FCC rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference and (2) This device must accept any interference received, including interference that may cause undesired operation.

This device is distributed by Alpha Wireless Automation

Alpha Wireless Automation
 1122 South Robertson Blvd. Suite 8
 Los Angeles, CA 90035

www.RemoteTank.com

Tel: 800-249-4249 or 310-249-4249 Fax: 310-385-7811